

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 45058
 Permit No. _____
 Basin. 10-1

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24929

1. OWNER J + D CONSTRUCTION ADDRESS AT WELL LOCATION CHOWBUCK
 MAILING ADDRESS MINDEN, NV MINDEN

2. LOCATION SE 1/4 SW 1/4 Sec. 35 T. 14 N. R. 20 E. DOUGLAS County
 PERMIT NO. 21-260-24 JOHNSON LANE Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy clay w/ boulders		0	6	6
Sand & gravel		6	42	36
Sandy clay w/ gravel		42	50	8
Sand & gravel some clay		50	110	60
Sandy clay w/ some gravel		110	145	35
Sandy clay		145	157	12
Sand		157	169	12
Sandy clay w/ coarse sand		169	240	71
Sandy clay w/ some gravel		240	268	28
Sandy clay w/ some coarse sand		268	279	11
grey sandy clay	X	279	296	17
course sand	XX	319	327	8
Sandy clay (grey)		327	334	7
course sand	XX	334	338	4
grey sandy clay		338	340	2

8. WELL CONSTRUCTION
 Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 340 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>340</u>

Perforations:
 Type perforation Factory slotted / T.C.
 Size perforation _____
 From T.C. 280 feet to 300 feet
 From Factory 320 feet to 340 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 340 feet

9. WATER LEVEL
 Static water level 210 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Warm °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION INC. Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV 89406
 Nevada contractor's license number 27673
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
 Signed Jerald W. Rhinell
 By driller performing actual drilling on site or contractor
 Date 4-27-94

Date started 94 4-21, 1994
 Date completed 4-27, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>20+</u>	<u>—</u>	<u>5</u>