

OFFICE USE ONLY
 Log No. 45059
 Permit No. _____
 Basin 107

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24764

1. OWNER Gary Garms ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 140 Hardie Lane Hardie Lane 1 mile East of Smith Hwy
Smith, NV 89430

2. LOCATION SE 1/4 NW 1/4 Sec. 28 T. 11 N/S R. 24 E. Lyon County
 PERMIT NO. NA Parcel No. NA Subdivision Name NA
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hard pan		0	3	3
Clay		3	8	5
Sand		8	12	4
Clay		12	23	11
Sand & gravel		23	42	19
Clay		42	51	9
Sand/gravel w/clay stringers		51	94	43
Gray clay		94	123	29
Brown clay w/coarse sand stringers	X	123	280	157

8. WELL CONSTRUCTION
 Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 280 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	17.02	.250	0	240

Perforations:
 Type perforation Mill slot
 Size perforation 3 x 1/8
 From 240 feet to 280 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 280 feet

9. WATER LEVEL
 Static water level 103 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address P.O. Box 590 Contractor
Winnemucca, NV 89446
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1562
 Signed C. E. Gephart
 By driller performing actual drilling on site or contractor
 Date 6-15-94

Date started March 3, 1994
 Date completed March 5, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	Approximately 100'	3 hours

1994 JUN 20 P 2:53
 STATE ENGINEERS OFF