



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO.

1. OWNER ARMAND HAMLETT ADDRESS AT WELL LOCATION 60 Friedhoff Ln, Yerington Nev 89442
 MAILING ADDRESS 201 Hwy 208 Yerington Nev 89442
 2. LOCATION SW 1/4 NE 1/4 Sec 13 T 12 N/S R 25 E Lyon County
 PERMIT NO. APN 12-351-061 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil - Clayish		0	3	3
Sandy - Clay		3	5	2
Clay - Sand		5	12	7
Coarse Sand		12	15	3
Clay		15	23	8
Coarse Sand		23	30	7
Coarse Sand + Small Gravel		30	42	12
Coarse Sand + Gravel to 1"		42	56	14
Coarse Sand + Gravel to 2"		56	76	20
Coarse Sand + Gravel to 2" + Few Rock	X	76	98	22

8. WELL CONSTRUCTION
 Depth Drilled 98 Feet Depth Cased 99 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 56' Feet
7 7/8 Inches 56' Feet 98' Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>1.088</u>	<u>71</u>	<u>98</u>

Perforations:
 Type perforation Sawed
 Size perforation 4 3/4 x 3 x 6 rows
 From 78 feet to 98 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 56 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 56 feet to 98 feet

9. WATER LEVEL
 Static water level 12' 6" feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.4 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ogden Bros Drilling Contractor
 Address 162 N. Bybee Lane Yerington NEV 89442 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
 Signed Log Ogden
 By driller performing actual drilling on site or contractor
 Date 1-20-94

Date started 94 12 15 1993
 Date completed 1 9 6 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Bailed</u>	<u>25</u>	<u>7</u>	<u>1/2 HR</u>
<u>Air Lift</u>	<u>80 plus</u>	<u>15</u>	<u>2 HRS</u>

JUN 27 P 4:30
 RECEIVED
 STATE ENGINEERS OFFICE