



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20494

1. OWNER Joe Fiddles ADDRESS AT WELL LOCATION 941 Highway 208 Yerington Nev. 89447
 MAILING ADDRESS 15 Nevada Rd. Yerington Nev.
 2. LOCATION NE 1/4 NE 1/4 Sec 35 T. 12 N/S R. 25 E Lyon County
 PERMIT NO. none | 12-371-07 | none
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0	9	9
sand gravel		9	18	9
clay		18	20	2
sand + gravel	X	20	31	11
sand + gravel Cobble stones	X	31	97	66
clay		97	101	4
sand gravel Cobble stones	X	101	130	29

'94 JUN 22 10:57 AM
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 130 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>		<u>1 8/8</u>	<u>1</u>	<u>130</u>

Perforations:
 Type perforation factory saw
 Size perforation 3/16 x 31
 From 110 feet to 130 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 8 feet to 130 feet

9. WATER LEVEL
 Static water level 20 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60 °F Quality good

Date started June 8 1994
 Date completed June 10 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>100</u>	<u>60</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Edmund Miller Contractor
 Address Box 92 Smiths Pt Contractor

Nevada contractor's license number issued by the State Contractor's Board 32166
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718

Signed Edmund Miller
 By driller performing actual drilling on site or contractor
 Date June 10 1994