WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45072
Permit No.
Basin 108

NOTICE OF INTENT NO.

1. OWNER Lawarnce O. Willingham
MAILING ADDRESS 2721 Yale Ave
Anaheim Ca. 92801

ADDRESS AT WELL LOCATION 595 Pete Hendricks Rd.
Yerington Nev 89447

2. LOCATION SW ¼ SW ¼ Sec. 35 T. 14 N/S R. 26 E. Lyon County
PERMIT NO. (Issued by Water Resources) 04-141-04 (Parcel No.) Lot 9 Hungry Horse Sub (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Sandy		0	3	3
Coarse Sand &				
Gravel - Fill		3	18	15
Coarse Sand &				
Gravel & Rock		18	36	18
Coarse Sand &				
Gravel - Fill		36	66	30
Coarse Sand &				
Gravel & Clay		66	120	54
Coarse Sand &				
Gravel & Clay & Rock		120	136	16
Coarse Sand &				
Gravel & Clay		136	156	20
Clay & Coarse Sand		156	165	9
Fine To Coarse				
Sand & Gravel Fill		165	180	15
Coarse Sand & Clay	X	180	186	6
Clay & Coarse Sand		186	200	14
Coarse Sand &				
Gravel	X	200	208	8

JUN 27 '94 P 4:30 STATE ENGINEER

Date started Feb 14, 1994
Date completed Feb 16, 1994

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	25	10	½

8. WELL CONSTRUCTION
Depth Drilled 208 Feet Depth Cased 209 Feet

HOLE DIAMETER (BIT SIZE)

		From		To
10 3/8	Inches	0	Feet	56 Feet
9 7/8	Inches	56	Feet	208 Feet
	Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	~~7.88~~	.188	+1	208
	12.92			

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3 x 6 Rows
From 188 feet to 208 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 208 feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. Bybee Lane (Contractor)
Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Larry Ogden (By driller performing actual drilling on site or contractor)
Date 3-21-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627