WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45073
Permit No.
Basin 108

NOTICE OF INTENT NO.

1. OWNER Alden Sipes
MAILING ADDRESS 14838 Studebaker Rd Norwalk Ca. 90650
ADDRESS AT WELL LOCATION 597 Rte Hendricks Rd Yerington Nev 89447

2. LOCATION Sw ¼ Sw ¼ Sec. 35 T. 14 N/S R. 26 E Lyon County
PERMIT NO. (Issued by Water Resources) 04-141-05 (Parcel No.) Lot 5 Hungry Horse Sub (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil - Sandy | | 0 | 3 | 3 |
| Coarse Sand + | | | | |
| Gravel - Fill | | 3 | 18 | 15 |
| Coarse Sand + | | | | |
| Gravel + Rock | | 18 | 36 | 18 |
| Coarse Sand + | | | | |
| Gravel - Fill | | 36 | 66 | 30 |
| Coarse Sand + | | | | |
| Gravel + Clay | | 66 | 120 | 54 |
| Coarse Sand + | | | | |
| Gravel + Clay + Rock | | 120 | 136 | 16 |
| Coarse Sand + | | | | |
| Gravel + Clay | | 136 | 156 | 20 |
| Clay + Coarse Sand | | 156 | 165 | 9 |
| Fine To Coars Sand | | | | |
| + Gravel Fill | | 165 | 180 | 15 |
| Coarse Sand + Clay | X | 180 | 186 | 6 |
| Clay + Coarse Sand | | 186 | 200 | 14 |
| Coarse Sand + | | | | |
| Gravel | X | 200 | 208 | 8 |
| Clay | | 208 | 209 | 1 |

Date started Feb 21, 19 94
Date completed Feb 23, 19 94

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Bailed | 25 | 10 | ½ |

8. WELL CONSTRUCTION
Depth Drilled 209 Feet Depth Cased 210 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 5/8 Inches | | 0 Feet | 56 Feet |
| 9 7/8 Inches | | 56 Feet | 209 Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.72 | .188 | +1 | 209 |

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3 x 6 Rows
From 189 feet to 209 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 209 feet

9. WATER LEVEL
Static water level 101.5 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. By Bee Lane (Contractor)
Yerington Nev
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Lay Ogden (By driller performing actual drilling on site or contractor)
Date 3-31-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627