

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER Laura Lowther ADDRESS AT WELL LOCATION 601 Pete Hendricks Rd  
MAILING ADDRESS 815 W. Bridge St. #28 Yerington NV 89442  
2. LOCATION SW 1/4 SW 1/4 Sec. 35 T. 14 N. R. 26 E. Lyon County Yerington  
PERMIT NO. 04-141-06 Parcel No. Lot 7 Hungry Horse Sub Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil - Sandy		0	3	3
Coarse Sand + Gravel-Fill		3	18	15
Coarse Sand + Gravel + Rock		18	36	18
Coarse Sand + Gravel-Fill		36	66	30
Coarse Sand + Gravel + Clay		66	120	54
Coarse Sand + Gravel + Clay + Rock		120	136	16
Gravel + Clay		136	156	20
Clay + Coarse Sand		156	165	9
Fine To Coarse Sand + Gravel		165	180	15
Coarse Sand + Clay	X	180	186	6
Clay + Coarse Sand		186	200	14
Coarse Sand + Gravel	X	200	208	8
Clay		208	209	1

STATE ENGINEER'S OFFICE  
JUN 27 1994

8. WELL CONSTRUCTION  
Depth Drilled 209 Feet Depth Cased 210 Feet

HOLE DIAMETER (BIT SIZE)  
From 0 To 56 Inches Feet  
56 To 209 Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>1292</u>	<u>1.88</u>	<u>±1</u>	<u>209</u>

Perforations:  
Type perforation Sawed  
Size perforation 4 1/2 x 3 x 6 holes  
From 189 feet to 209 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
 Cement Grout  
Placement Method:  Pumped  Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 209 feet

9. WATER LEVEL  
Static water level: 10.3 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Ogden Bros Drillings Contractor  
Address 162 N. B. Bee Lane Contractor  
Yerington Nev 89442  
Nevada contractor's license number 15646  
issued by the State Contractor's Board  
Nevada driller's license number issued by the 634  
Division of Water Resources, the on-site driller.  
Signed Larry Ogden  
By \_\_\_\_\_ after performing actual drilling on site or contractor  
Date 3-21-94

Date started Feb 28 1994  
Date completed March 2 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>Bailed</u>	<u>25</u>	<u>10</u>	<u>1/2</u>