WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45075
Permit No.
Basin 108

NOTICE OF INTENT NO.

1. OWNER Bob & Allene Ingersoll ADDRESS AT WELL LOCATION Same
MAILING ADDRESS 573 RR Henricks Rd
Yerington Nev 89447

2. LOCATION SE ¼ SE ¼ Sec. 34 T. 14 N/S R. 26 E/W Lyon County
PERMIT NO. (Issued by Water Resources) APN # 14-381-17 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvial Gravel				
(well Rock)		119	120	1
Brown Clay		120	124	4
Coarse Sand		124	129	5
Brown Clay		129	135	6
Coarse Sand		135	146	11
Brown Clay		146	160	14
Coarse Sand		160	162	2
Brown Clay		162	168	6
Coarse Sand		168	170	2
Brown Clay		170	185	15
Fill - Fine to				
Coarse Sand &				
Gravel		185	205	20
Red Clay		205	206	1
Coarse Sand &				
Gravel & Rock Fill	X	206	220	14
Casing - 3'				
Below Ground				
in Block Building				
1' above concrete				
Floor				
216'/5" casing				
in well				

Date started 3-9, 1994
Date completed 3-11, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR LIFT	40 plus		3 HRS
AIR LIFT	FROM	200'	

8. WELL CONSTRUCTION
Depth Drilled 219 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
5 7/8"	120	~~220~~ 219

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	9.66	.188	-3	~~220~~ 219

Perforations:
Type perforation ~~3~~ Sawed
Size perforation 3/32 X 3 5 Rows
From 199 feet to 219 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal —
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From — feet to — feet

9. WATER LEVEL
Static water level 53 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. Big Bee Lane (Contractor)
Yerington Nev
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Jay Ogden (By driller performing actual drilling on site or contractor)
Date 3-14-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627