WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45079
Permit No.
Basin 131

NOTICE OF INTENT NO. 26890

1. OWNER Battle Mountain Gold
MAILING ADDRESS P.O. Box 1627
Battle Mountain, NV 89820

ADDRESS AT WELL LOCATION Hole # CM-29
Battle Mountain Gold

2. LOCATION SW ¼ NW ¼ Sec. 3 T 30 N/S R 43 E Lander County

PERMIT NO. M/O-651 (Issued by Water Resources) | NA (Parcel No.) | NA (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvian		0	108	108
Consolidated alluvian		108	112	4
Alluvian		112	190	78
Volcanic basalt		190	270	80
Sand & gravel w/some clay		270	360	90

Cement 0 - 56'
Gravel 56' - 190'
Cement 190' - 204'
Bentonite 204' - 206'
Gravel 206' - 265'
Cement 265' - 285'
Bentonite 285' - 287'
Gravel 287' - 360'

Date started May 11, 19 94
Date completed May 14, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1		9

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 1/4 Inches		0 Feet	360 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	SCH 80	0	295
2	PVC	SCH 80	355	360
1	PVC	SCH 80	0	295
1	PVC	SCH 80	355	360

Perforations:
Type perforation .050 PVC Screen
Size perforation SCH 80
From 2" 295 feet to 355 feet
From 1" 295 feet to 355 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 56'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 308.9 feet ~~below land surface~~ from top of casing.
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address P.O. Box 590 (Contractor)
Winnemucca, NV 89446
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1713
Signed C. E. Epple (By driller performing actual drilling on site or contractor)
Date 6-21-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627