

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25274

1. OWNER STEVE & CAROL WILMANS ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS RT 2 BOX 13 R O LIVESTOCK RANCH
ROUND MOUNTAIN NEVADA 89045 ROUND MOUNTAIN NEVADA
 2. LOCATION NE 1/4 NE 1/4 Sec. 9 T 12 N3 R 43 E NYE County
 PERMIT NO. W-398 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	15	15
GRAVEL & SM CLAY LAYERS		15	53	38
GRAVEL		53	65	12
CLAY		65	74	9
GRAVEL		74	80	6
CLAY & COURSE SAND		80	86	6
COURSE SANDS		86	95	9
CLAY & COURSE SAND		95	100	5
GRAVEL & SAND		100	108	8
CLAY		108	111	3
GRAVEL		111	115	4
CLAY		115	117	2
SM GRAVEL & CLAY LAYERS		117	130	13
CLAY		130	138	8
SM GRAVEL & CLAY LAYERS		138	150	12
GRAVEL & COURSE SAND		150	165	15
GRAVEL & CLAY		165	170	5
GRAVEL & SAND		170	186	16
CLAY, GRAVEL, SAND LAYERS		186	207	21
CLAY & COURSE SAND		207	215	8
CLAY, GRAVEL, COURSE SAND LAYERS		215	225	10
GRAVEL & COURSE SAND		225	227	2
CLAY, GRAVEL, SAND LAYERS		227	261	34
GRAVEL & SAND		261	264	3
CLAY, GRAVEL, SAND LAYERS		264	279	15
GRAVEL, SAND, TRACE CLAY		279	303	24
SANDY CLAY		303	325	22
SEE ATTACHED SHEET				

8. WELL CONSTRUCTION
 Depth Drilled 480 Feet Depth Cased 480 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
34 Inches 0 Feet 53 Feet
24 Inches 53 Feet 480 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	.250	42.05	0	230

Perforations:
 Type perforation JOHNSON WELL SCREEN
 Size perforation 16" X .250
 From 0 feet to 250 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 53 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 53 feet to 480 feet

9. WATER LEVEL
 Static water level 10 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD


10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name SARGENT IRRIGATION COMPANY Contractor
 Address 9955 NORTH VIRGINIA STREET Contractor
RENO NEVADA 89506
 Nevada contractor's license number 0021246 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1413
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date JUNE 28, 1994

Date started APRIL 18, 1994
 Date completed JUNE 27, 1994

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
<u>500</u> G.P.M.	<u>178</u>	<u>24</u>

Log # 45082
Page 2



NOTICE OF INTENT NO.: 25274
PERMIT NO.: W-398

R O LIVESTOCK RANCH
ROUND MOUNTAIN NEVADA

LITHOLOGIC LOG CONTINUED...

COURSE SAND & CLAY LAYERS	325	390	65
COURSE SAND W/TRACE CLAY	390	401	11
SANDY CLAY & SAND	401	412	11
COURSE SAND W/TRACE CLAY	412	441	29
SANDY CLAY & COURSE SAND	441	463	22
SANDY CLAY	463	480	17