



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15269

1. OWNER Bank of America ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 700 Fullerton Street Ely NV

2. LOCATION SE 1/4 SW 1/4 Sec 15 T 16 S R 63 E White Pine County
 PERMIT NO. MO 660 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG MMW-2

Material	Water Strata	From	To	Thick-ness
<u>Asphalt</u>	<u>No</u>	<u>0</u>	<u>1.5</u>	<u>1.5</u>
<u>Silty Sand</u>	<u>No</u>	<u>1.5</u>	<u>9.0</u>	<u>8.5</u>
<u>Sand</u>	<u>No</u>	<u>9.0</u>	<u>14.0</u>	<u>5.0</u>
<u>Sandy silt</u>	<u>No</u>	<u>14.0</u>	<u>17.0</u>	<u>3.0</u>
<u>Gravel</u>	<u>No</u>	<u>17.0</u>	<u>19.0</u>	<u>2.0</u>
<u>Sandy silt</u>	<u>Yes</u>	<u>19.0</u>	<u>28.0</u>	<u>9.0</u>

8. WELL CONSTRUCTION
 Depth Drilled 28 Feet Depth Cased 28 Feet

HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 28 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>sch. 40</u>	<u>0</u>	<u>28</u>

Perforations:
 Type perforation Factory slot
 Size perforation 1.00

From 13 feet to 28 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 12 feet to 28 feet

RECEIVED
 JUN 16 1994

STATE ENGINEER'S OFFICE

Date started 4-28, 1993
 Date completed 4-28, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
		<u>N/A</u>	

9. WATER LEVEL
 Static water level 22.4 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature 66.0 °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Anderson Exploration Drilling Contractor
 Address 1635 Belford Rd. Reno NV Contractor

Nevada contractor's license number issued by the State Contractor's Board 34525
 Nevada driller's license number issued by the Division of Water Resources, He on-site driller m 1667

Signed John Anderson
 By driller performing actual drilling on site or contractor
 Date 6/1/94