WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45122 In Book
Permit No.
Basin 212

NOTICE OF INTENT NO. 12155

1. OWNER DAVE MASON / GAUDIN FORD
MAILING ADDRESS 40 BROADBENT & ASSOC. 833 NEVADA HWY STE 4 BOULDER CITY 89005
ADDRESS AT WELL LOCATION FORMER GAUDIN FORD, 4th ST & LAS VEGAS BLVD SOUTH

2. LOCATION NE ¼ NW ¼ Sec. 13 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. MD-2395 Issued by Water Resources
040-270-002 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-5
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT / FILL		0	4½	4½
SAND - SILT - CLAY MIX		4½	7	2½
PART. CMT GRAVEL		7	7½	½
SILTY CLAY		7½	20	12½

RECEIVED
FEB 25 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started FEBRUARY 3, 1994
Date completed FEB 3, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	20 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	20

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-1/1-3' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 3 feet to 20 feet

9. WATER LEVEL
Static water level 8.27 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGH Contractor
Address 4670 So. POLARIS AVE Contractor
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
Signed By driller performing actual drilling on site or contractor
Date FEBRUARY 22 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627