WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45139
Permit No. 51591
Basin 209

NOTICE OF INTENT NO. 10456

1. OWNER Elwyn Robinson
MAILING ADDRESS P.O. Box 153 Alamo Nev. 89001
ADDRESS AT WELL LOCATION 1 mile west on Sharp Ranch Road Alamo Nev.

2. LOCATION N/E ¼ S/E ¼ Sec. 21 T. 7 N/S R. 61 E. Lincoln County
PERMIT NO. 51591 (Issued by Water Resources) | Parcel No. — | Subdivision Name —

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [X] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	8	8
cemented gravel		8	60	52
coarse sand - boulders	X	60	94	34
Hard Rock		94	96	2
TD 96'				

RECEIVED
JUL 12 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 10-7-93, 19
Date completed 10-15-93, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
air test	190	unknown	2

8. WELL CONSTRUCTION
Depth Drilled 96 Feet Depth Cased 96 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	96 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	—	.188	0	96

Perforations:
Type perforation factory
Size perforation 1/8" x 3"
From 56 feet to 96 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 20'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 20 feet to 96 feet

9. WATER LEVEL
Static water level 20' feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling (Contractor)
Address P.O. Box 54 Hiko Nev. 89017 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0028866
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis (By driller performing actual drilling on site or contractor)
Date 7-4-93