WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45144
Permit No.
Basin 162

NOTICE OF INTENT NO. 10915

1. OWNER Mike Ham
MAILING ADDRESS Box 8073
Pahrump Nevada 89041

ADDRESS AT WELL LOCATION
Unit #3 Block 5 Lot #5
Jarvis St

2. LOCATION N½ ¼ ¼ Sec 28 T 19S N/S R 53 E Nye County
PERMIT NO. (Issued by Water Resources) 29-901-305 (Parcel No.) Bell Vista Sub (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 1 | 1 |
| Brn Clay | | 1 | 4 | 3 |
| Hard Brn Clay | | 4 | 11 | 7 |
| Brn Clay | | 11 | 24 | 13 |
| Hard Brn Clay | | 24 | 30 | 6 |
| Hard Grey Caliche | | 30 | 46 | 16 |
| Hard Brn Clay | | 46 | 51 | 5 |
| Brn Clay | WB | 51 | 69 | 18 |
| Hard Grey Clay | | 69 | 81 | 12 |
| Brn Clay | | 81 | 120 | 39 |
| Brn Clay | | 120 | 150 | 30 |
| Hard Grey Clay | | 150 | 160 | 10 |

RECEIVED
AUG 22 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Aug 6, 1994
Date completed Aug 11, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12½ Inches | | 0 Feet | 160 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | 17.11 | 188 | 0 | 160 |
| | | | | |
| | | | | |

Perforations:
Type perforation Torch Cut
Size perforation ¼" x 6"
From 100 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 160 feet to 50 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ron Mallow Drilling (Contractor)
Address Box 265 Pahrump Nev 89041 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0035704
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1625
Signed Ron Mallow (By driller performing actual drilling on site or contractor)
Date Aug 12 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627