

Log No. 42150  
 Permit No. \_\_\_\_\_  
 Basin G-91

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21833

1. OWNER ROBERT HERSCHBACH ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1440 Coupler Way #14 325 Silvan Crt  
Sparks, NV 89434 Verdi, NV 89439  
 2. LOCATION SW 1/4, SE 1/4 Sec. 7 T. 19N N/S R. 18 E Washoe County  
 PERMIT NO. new app # 38-841-03 638-047-03 Verdi Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE  
 New Well  Replace  Recondition  Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Deepen  Abandon  Other \_\_\_\_\_  Municipal/Industrial  Monitor  Stock  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil, some gravels		0	1	1
Boulders gravels with brown clay		1	22	21
Brown clay		22	55	33
Green clay		55	91	36
Dark brown clay		91	122	31
Black volcanic rock		122	144	22
Fracture rock	X	144	151	7
Black volcanic rock		151	159	8
Fracture rock		159	171	12
Black volcanic rock	X	171	175	4

see deepening log # 111374  
 39,521, 061°N NAD27 O.D.  
 120,000, 806°W

8. WELL CONSTRUCTION  
 Depth Drilled 175 Feet Depth Cased 175 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 50 Feet  
 From 8 5/8 Inches To 175 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	175

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 130 feet to 170 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 175 feet

9. WATER LEVEL  
 Static water level 25 feet below land surface  
 Artesian flow 25 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370 Contractor  
Reno, NV 89510  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date June 17, 1993

Date started 6-15-93, 19\_\_\_\_  
 Date completed 6-16-93, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			