


OFFICE USE ONLY  
 Log No. 45154  
 Permit No. 162  
 Basin 162



WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Jonathan Helman ADDRESS Pahrump  
 2. LOCATION NE 1/4 SE 1/4 Sec. 5 T. 19 N. R. 53 E. Clark County  
 PERMIT NO. \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Boulders & gravel		0	200	200
Consolidated gravel & boulders	X	200	265	65

8. WELL CONSTRUCTION  
 Diameter hole 9 5/8 inches Total depth 265 feet  
 Casing record 6 5/8"  
 Weight per foot \_\_\_\_\_ Thickness 188  
 Diameter 6 5/8 inches From + feet To 265 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Cement  
 Depth of seal 50 ft feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 265 feet  
 Perforations:  
 Type perforation torch  
 Size perforation 1/4" x 8"  
 From 205 feet to 265 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 AUG 30 1994  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 8-8-14 1994  
 Date completed 8-16 1994

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>406.45</u>		<u>3 hrs</u>

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 180 Feet below land surface  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature Cool F. Quality DH

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Mitchell Enterprises  
 Address 2255 E. Sunset Rd #1056 - LVND  
 Nevada contractor's license number 27030  
 Nevada driller's license number 1475  
 Signed Dean Mitchell  
 Date 8/21/94