

PRINT OR TYPE ONLY
 O NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26453

1. OWNER Clayton Overby ADDRESS AT WELL LOCATION Lot 15 Windmill Rd
 MAILING ADDRESS White Wolf Meadows
 2. LOCATION W 1/2 of E 1/2 Sec. 8 T 4 R 36 E Esmeralda County
 PERMIT NO. _____ Parcel No. 15 Subdivision Name White Wolf Meadows
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	3	3
Rocks		3	7	4
Sand		7	28	21
gravels		28	31	3
Sand		31	40	9
Hard Pan Clay		40	46	6
Sand		46	64	18
gravels		64	65	1
Sand		65	77	12
Clays		77	80	3
Sands coarse	X	80	87	7
clays		87	89	2
Sands (coarse)	X	89	99	10
Clays & Fine Sands		99	114	15
Hardpan Clay		114	116	2
Clays mixed with fine and coarse Sands		116	134	18
Clays with coarse	X	134	156	22
Sands				
Rocks	X	156	158	2
clay		158	160	2
coarse sands	X	160	172	12
clays with sand		172	180	8
Sands with clay	X	180	188	8
clay		188	190	2
Sands	X	190	200	10

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 7/8 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.92</u>	<u>.188</u>	<u>0</u>	<u>200</u>

Perforations:
 Type perforation mill slot
 Size perforation 7/32 x 3" x 5 rows
 From 140 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 55
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 200 feet to 55 feet

9. WATER LEVEL
 Static water level 117 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 62 °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Inland Pacific Drilling Co Inc Contractor
 Address Po Box 831 Yerington NV 89447 Contractor

Date started 1994 August 7th
 Date completed August 9th

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>RECEIVED</u>	<u>3 HRS</u>
<u>AIRLIFT</u>	<u>20</u>	<u>RECEIVED</u>	<u>6 HRS</u>
		<u>AUG 29 1994</u>	
		<u>Div. of Water Resources</u>	
		<u>Branch Office - Las Vegas, NV</u>	

Nevada contractor's license number issued by the State Contractor's Board 0036582
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 12217-11221
 Signed Joel W. Brown
 By driller performing actual drilling on site or contractor
 Date August 9 1994