WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45161
Permit No.
Basin 162

NOTICE OF INTENT NO. 11829

1. OWNER VERN NEBLOCK
MAILING ADDRESS 5009 EVERGREEN #2
LAS VEGAS, NV 89107

ADDRESS AT WELL LOCATION
PROSPECTOR, OFF BARNEY

2. LOCATION NE ¼ SW ¼ Sec. 18 T. 20 N/S R. 53 E. NYE County
PERMIT NO. (Issued by Water Resources) Parcel No. 91 Subdivision Name CHAS. PK RANCHOS

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN STICKY CLAY		0	6	6
HARD BROWN CLAY		6	20	14
SOFT BROWN CLAY	x	20	36	16
SANDY CLAY	x	36	38	2
LIGHT BROWN CLAY		38	110	72
SANDY BROWN CLAY	x	110	116	6
SOFT BROWN CLAY		116	140	24
SOFT SANDY BR. CLAY	x	140	150	10
STICKY DK BR CLAY		150	160	10

RECEIVED
AUG 30 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 8-3, 1994
Date completed 8-17, 1994

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	25'	1/2 HR

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 161 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	18	188	0	160

Perforations:
Type perforation FACTORY CUT
Size perforation 1/8 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 160 feet

9. WATER LEVEL
Static water level 41 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GULLARD DRILLING (Contractor)
Address 6022 S. EUCLID AVE (Contractor)
LAS VEGAS, NV 89120
Nevada contractor's license number issued by the State Contractor's Board 4796
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 115
Signed O M Gullard (By driller performing actual drilling on site or contractor)
Date 8/20/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627