

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13297

1. OWNER Green rock const ADDRESS AT WELL LOCATION Gills way
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 SE 1/4 Sec. 18 T. 21S N/S R. 54 E Nye County
 PERMIT NO. 45-121-33 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Cobbles</u>		<u>0</u>	<u>27</u>	<u>27</u>
<u>Clay</u>		<u>27</u>	<u>34</u>	<u>7</u>
<u>Gravel</u>		<u>34</u>	<u>62</u>	<u>28</u>
<u>Limestone</u>		<u>62</u>	<u>67</u>	<u>5</u>
<u>Clay</u>		<u>67</u>	<u>195</u>	<u>128</u>
<u>Clay Gravel</u>	<u>tr</u>	<u>195</u>	<u>290</u>	<u>95</u>
<u>Gravel</u>	<u>ws</u>	<u>290</u>	<u>300</u>	<u>10</u>

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 296 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 300 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>296</u>

Perforations:
 Type perforation Factory Sealant
 Size perforation 1/2" x 3"
 From 274 feet to 296 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 296 feet

RECEIVED

JUL 22 1994

Div of Water Resources
 Branch Office - Las Vegas, NV

Date started 6-14, 1994
 Date completed 6-17, 1994

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 40 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HR 78 Box 80358 Contractor
Rahump NV 89041
 Nevada contractor's license number 30880
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1642
 Division of Water Resources, the on-site driller
 Signed Thomas Dean
 By driller performing actual drilling on site or contractor
 Date 7/5/94