



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10914

1. OWNER JERRY CAUENDER ADDRESS AT WELL LOCATION BARNEY ST
 MAILING ADDRESS Box 3680 Lot # 4
PAHRUMP NEV 89041
 2. LOCATION NE 1/4 SE 1/4 Sec 36 T 19S N/S R 52 E NYE County
 PERMIT NO. 27-171-43 NONE Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil		0	5	5
GREY CLAY		5	30	25
GREY CLAY	WB	30	50	20
BROWN CLAY	WB	50	140	90
FINE GRAVEL				
FIRST WATER				
34'				

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/2 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>	<u>19.11</u>	<u>1.88</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Torch Cut
 Size perforation 1/4 x 6"
 From 90 feet to 140 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 140 feet to 50 feet

RECEIVED

AUG 03 1994

Div. of Water Resources
 Branch Office - Las Vegas NV

Date started July 25 1994
 Date completed July 28 1994

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 34 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ron Nailon Drilling Contractor
 Address Box 265 PAHRUMP NEV 89041 Contractor
 Nevada contractor's license number 0035704
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1625
 Signed Ron Nailon
 By driller performing actual drilling on site or contractor
 Date AUG 1 1994

