


WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



Log No. 45285
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 12823

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Rusty Cooper ADDRESS AT WELL LOCATION Lot 39 White Wind
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 NW 1/4 Sec 1 T. 21S N/S R. 53 E Nye County _____
 PERMIT NO. 44-131-11 Parcel No. _____ Subdivision Name Molehead Ranch

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Caliche		3	7	4
Clay		7	32	25
Caliche		32	34	2
Clay		34	53	19
Caliche		53	58	5
Clay		58	88	30
Caliche	WB	88	90	2
Clay		90	99	9
Caliche	WB	99	102	3
Clay		102	115	13
Caliche	WB	115	121	6
Clay		121	130	9
Caliche	WB	130	132	2
Clay		132	140	8

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.90</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory Saw Cut
 Size perforation 1/2 x 3
 From 100 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

RECEIVED
 MAY 25 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 4/6 1994
 Date completed 4/8 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 54 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge. **I**
 Name Great Basin Drilling Contractor
 Address 40278 Box 80358 Contractor
Pahrump NV 89041
 Nevada contractor's license number 30880
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas D...
 By driller performing actual drilling on site or contractor
 Date 5/16/94