WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45289
Permit No.
Basin 212

NOTICE OF INTENT NO. 13065

1. OWNER CLARK COUNTY SCHOOL DISTRICT
MAILING ADDRESS 1700 GALLERIA BLDG C
HENDERSON, NV 89014

ADDRESS AT WELL LOCATION R.C. WHITE TRANSPORTATION FACILITY, 4499 SOUTH ARVILLE ST, LAS VEGAS NV

2. LOCATION SE ¼ NW ¼ Sec. 19 T 21 N/S R 61 E CLARK County
PERMIT NO. MO-2409 Issued by Water Resources | 140-370-008 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-101
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT/FILL		0	1	1
SANDY CLAY		1	4	3
CALICHE		4	5.5	1.5
SILTY SAND		5.5	6.5	1
SANDY CLAY		6.5	7	0.5
CALICHE		7	8	1
POORLY GRADED SAND		8	10	2
SANDY CLAY		10	17	7
CLAYEY GRAVEL		17	20	3
SILTY SAND		20	24	4
SILTY CLAY		24	30	6
CALICHE		30	35	5
SILTY CLAY		35	45	10

Date started MARCH 2, 1994
Date completed MARCH 7, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
MAR 10 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 45 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	45 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	1.9	0.237	0	35

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 7.5 feet to 22.5 feet
From 32.5 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-3/3-5 AND 28-30' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 5-28 AND 30-35 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGH
Address 4670 SOUTH POLARIS AVE
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources M 1869
Signed
By driller performing actual drilling on site or contractor
Date MARCH 9, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627