WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK.

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45290
Permit No.
Basin 212

NOTICE OF INTENT NO. 13065

1. OWNER CLARK COUNTY SCHOOL DISTRICT
MAILING ADDRESS 1700 GALLERIA, BLDG C
HENDERSON, NV 89014

ADDRESS AT WELL LOCATION RC WHITE TRANSPORTATION FACILTY 4499 SOUTH ARVILLE ST, LAS VEGAS NV

2. LOCATION SE ¼ NW ¼ Sec. 19 T. 21 N/S R 61 E CLARK County
PERMIT NO. MO-2409 Issued by Water Resources
140-370-008 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-103
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT/FILL		0	1	1
SILTY SAND		1	6	5
CALICHE		6	7.5	1.5
SILTY SAND		7.5	9	1.5
CALICHE		9	11.5	2.5
SILTY SAND		11.5	12.5	1
SANDY CLAY		12.5	14	1.5
SANDY SILT		14	15	1
CLAYEY GRAVEL		15	19	4
SANDY CLAY		19	21	2
SILTY CLAY		21	26	5
SANDY CLAY		26	32	6
CALICHE		32	37	5
CLAY		37	45	8

RECEIVED
MAR 10 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started MARCH 2, 1994
Date completed MARCH 4, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 45 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	45 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	1.9	0.237	0	40

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 12.5 feet to 27.5 feet
From 37.5 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-8'/8-10' AND 32-34' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 10-32' feet to AND 34-45 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGH
Contractor
Address 4670 SO. POLARIS AVE
Contractor
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on site driller M 1869
Signed
By driller performing actual drilling on site or contractor
Date MARCH 9, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627