WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45294
Permit No.
Basin

NOTICE OF INTENT NO. 13281

1. OWNER SHELDON GOTTSCHALK
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1830 E HERITAGE
PAHRUMP NV 89041

2. LOCATION SE ¼ NE ¼ Sec. 11 T 21S N/S R 53 E NYE County
PERMIT NO. (Issued by Water Resources) 44-303-15 (Parcel No.) JOYCELYN ESTATES (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	2	2
CALICHIE		2	4	2
CLAY		4	19	15
CALICHIE		19	23	4
CLAY		23	39	16
CALICHIE		39	43	4
CLAY		43	54	11
CALICHIE	WB	54	58	4
CLAY		58	76	18
CALICHIE	WB	76	78	2
CLAY		78	89	11
CALICHIE	WB	89	95	6
CLAY		95	104	9
CALICHIE	WB	104	107	3
CLAY		107	119	12
CALICHIE	WB	119	123	4
CLAY		123	134	11
CALICHIE	WB	134	140	6
		140		140

RECEIVED
JUN 29 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 5-27-94, 19
Date completed 5-28-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
121\4 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85\8	16.9	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1\8 X 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 56 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. INC. (Contractor)
Address HCR 78 BOX 80358 (Contractor)
PAHRUMP NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 6-10-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627