


PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



1. OWNER Don & Lenore Bemis ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NW 1/4 SE 1/4 Sec 36 T 21-S N/S R 53 E Nye County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Parcel No. 4 Subdivision Name Homestead Garden

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Brown Clay		4	44	40
Grey Clay		44	75	31
Brown Clay		75	92	17
Broken Sandstone (no mud)	x	92	155	63
Brown Clay		155	188	33
Gypsum Formation	x	188	196	8
Brown Clay		196	200	4

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet ~~248~~ Depth Cased 200 Feet ~~248~~  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
12 Inches 0 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	18 lbs	.188	0	200

Perforations:  
 Type perforation Torch Cut  
 Size perforation 1/4 in width 8 in long  
 From 160 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 JUN 21 1994  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 5.0  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 5.0 feet to 200 feet

9. WATER LEVEL  
 Static water level 77 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Charles Nyberg Contractor  
 Address HCR 77 Box 36525 Contractor  
 Nevada contractor's license number 7484 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725  
 Signed Charles Nyberg By driller performing actual drilling on site or contractor  
 Date 6-16-94

Date started June 1 1994  
 Date completed June 4 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/4