WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45330
Permit No.
Basin 162

NOTICE OF INTENT NO. 13305

1. OWNER NANCY NORBY
MAILING ADDRESS
ADDRESS AT WELL LOCATION LOT 144 DONNER
PAHRUMP NV 89041

2. LOCATION SW ¼ NW ¼ Sec. 13 T. 20S N/S R. 52 E. NYE County
PERMIT NO. (Issued by Water Resources) 28-713-12 (Parcel No.) CHARLESTON PARK (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	3	3
CALICHIE		3	6	3
CLAY		6	13	7
CALICHIE		13	15	2
CLAY		15	22	7
CALICHIE		22	25	3
CLAY		25	38	13
CALICHIE		38	41	3
CLAY		41	54	13
CALICHIE	WB	54	57	3
CLAY		57	68	11
CALICHIE	WB	68	71	3
CLAY		71	84	13
CALICHIE	WB	84	106	22
CLAY		106	110	4
CALICHIE	WB	110	121	11
CLAY		121	123	2
CALICHIE	WB	123	135	12
CLAY		135	137	2
CALICHIE	WB	137	140	3
		140		140

RECEIVED
AUG 02 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 6-24-94, 19
Date completed 6-25-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12.25	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85\8	16.9	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1\8 X 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. INC. (Contractor)
Address HCR 78 BOX 80358 (Contractor)
PAHRUMP NV 89041

Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dr (By driller performing actual drilling on site or contractor)
Date 6-23-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627