


OFFICE USE ONLY
 Log No. 45352
 Permit No. _____
 Basin 212



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12159

1. OWNER AMERICAN MINIMART ADDRESS AT WELL LOCATION SEC OF LINDELL AND CHARLESTON BLVD
 MAILING ADDRESS 5525 WEST CHARLESTON LAS VEGAS, NV

2. LOCATION NW 1/4 NW 1/4 Sec. 1 T. 21 N. R. 60 E. CLARK County

PERMIT NO. MD-2394 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE MW-5
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>WELL GRADED SAND</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>SILTY SAND</u>		<u>10</u>	<u>20</u>	<u>10</u>
<u>SAND SILT CLAY MIX</u>		<u>20</u>	<u>32</u>	<u>12</u>
<u>CEMENTED GRAVEL</u>		<u>32</u>	<u>35</u>	<u>3</u>
<u>SILTY CLAY</u>		<u>35</u>	<u>53</u>	<u>18</u>
<u>CEMENTED GRAVEL</u>		<u>53</u>	<u>56</u>	<u>3</u>
<u>SILTY CLAY</u>		<u>56</u>	<u>65</u>	<u>9</u>

8. WELL CONSTRUCTION
 Depth Drilled 65 Feet Depth Cased 65 Feet

HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 65 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.64</u>	<u>0.154</u>	<u>0</u>	<u>65</u>

Perforations:
 Type perforation FACTORY SLOT
 Size perforation 0.020

From 40 feet to 65 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-9 1/2'-19 1/2'-11 1/2' BENTONITE Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 1 1/2 feet to 65 feet

RECEIVED
 FEB 25 1994
 Div. of Water Resources
 Branch Office Las Vegas, NV

Date started FEB 17, 1994
 Date completed FEB 17, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 51.16 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name THOMAS HIGH Contractor
 Address 4670 SO. POLARIS AVE
LAS VEGAS NV 89103 Contractor

Nevada contractor's license number issued by the State Contractor's Board _____

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869

Signed Thomas High
 By driller performing actual drilling on site or contractor

Date FEB 25, 1994