WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45366
Permit No.
Basin 09213

NOTICE OF INTENT NO. 27292

1. OWNER: BOB FOSTER
MAILING ADDRESS: 5370 Butter Fly Crt. Reno, NV 89523
ADDRESS AT WELL LOCATION: 7615 Alameda Reno, NV 89506

2. LOCATION: SW ¼ SE ¼ Sec. 6 T. 20N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 088-082-24 (Parcel No.) Golden Valley (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL DEEPENING:				
Static 205, 6 foot fill in bottom, clean out makes 1 GPM.				
Gray granite		230	245	15
Fracture (NO WATER)		245	246	1
Gray granite		246	296	50
Weathered granite, soft zone (1 GPM)	X	296	298	2
Gray granite		298	310	12
Soft granite with clay streaks		310	380	70
Gray granite		380	394	14
Fracture (EST 11 GPM)	X	394	395	1
Gray granite		395	405	10
Fracture	X	405	406	1
Gray granite		406	421	15

Date started 8-15-94, 19
Date completed 8-17-94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
23		

8. WELL CONSTRUCTION
Depth Drilled 421 Feet Depth Cased 421 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
6 1/8	230	421

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	421

Perforations:
Type perforation: factory sawed slot
Size perforation: 3/32 x 3 x 5 around
From 214 feet to 234 feet
From 274 feet to 294 feet
From 374 feet to 414 feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal: deepening
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 230 feet to 421 feet

9. WATER LEVEL
Static water level 205 feet below land surface
Artesian flow G.P.M. 23 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): Wayne Drilling, Inc.
Address (Contractor): P.O. Box 12370 Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board: 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 923
Signed (By driller performing actual drilling on site or contractor)
Date: August 24, 1994

(Rev. 3 91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627