

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27293

1. OWNER TOM HAUPTMAN ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. BOX 1884 1413 Clement Court  
Sparks, NV 89432 Reno, NV 89506  
 2. LOCATION SE 1/4 SE 1/4 Sec. 23 T. 22N. N/S R. 19 E. Washoe County  
 PERMIT NO. 079-470-35 Antelope Valley Park Estates #268  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Sandy clay		1	8	7
Brown clay, some streaks of sand		8	21	13
Weathered granite some streaks of clay		21	55	34
Weathered granite		55	110	55
Gray granite		110	138	28
Soft zone	X	138	142	4
Gray granite		142	168	26
Fractured granite	X	168	170	2
Gray granite		170	204	34
Fracture	X	204	206	2
Gray granite		206	219	13
Fracture	X	219	220	1
Gray granite		220	225	5

8. WELL CONSTRUCTION  
 Depth Drilled 225 Feet Depth Cased 225 Feet  
 HOLE DIAMETER (BIT SIZE)  

Inches	From	To
10	0	50
8 5/8	50	225

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	225

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 140 feet to 150 feet  
 From 170 feet to 180 feet  
 From 200 feet to 220 feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 225 feet

9. WATER LEVEL  
 Static water level 131 feet below land surface  
 Artesian flow G.P.M. 20 P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NV 89510  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date August 25, 1994

Date started 8-23-94, 19\_\_\_\_  
 Date completed 8-24-94, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)