

OFFICE USE ONLY
 Log No. 45384
 Permit No. _____
 Basin 162

 13389

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13389

1. OWNER Robert Pritchett ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____ 801 E. Dixieland
 2. LOCATION SE 1/4 NE 1/4 Sec. 10 T. 21-S N/S R. 53 E. Nye County _____
 PERMIT NO. 44-254-08 Plantation Est. Subdivision Name _____
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Gray clay		4	12	8
Brown clay		12	21	9
Gray clay		21	37	16
Brown clay/caliche	X	37	68	31
Gray clay/caliche		68	83	15
Brown clay/caliche	X	83	105	22
Limestone		105	112	7
Brown clay/caliche	X	112	155	43
Limestone	X	155	160	5

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	160

Perforations:
 Type perforation Torch Cut
 Size perforation 1/4" width 8" long
 From 120 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 49 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name JIM PIKE WELL DRILLING, LLC Contractor
 Address P.O. Box 56 Contractor
Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 17563
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812
 Signed William A. Farnell
 By driller performing actual drilling on site or contractor
 Date July 21, 1994

Date started July 18, 1994
 Date completed July 18, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/2

RECEIVED

AUG 11 1994

Div. of Water Resources
 Branch Office - Las Vegas, NV

