WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45393
Permit No.
Basin

NOTICE OF INTENT NO. 13679

1. OWNER MR. ED HORAK
MAILING ADDRESS 5900 MELLO AVENUE
LAS VEGAS, NV 89131

ADDRESS AT WELL LOCATION
MELLO AVENUE

2. LOCATION NW ¼ SW ¼ Sec. 24 T. 19S N/S R. 60 E CLARK County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILT, CLAY, POPCORN		0	14	14
CALECHI		14	16	2
SILT, CLAY, SOME GRAVEL		16	80	64
CEMENTED CONGLOMERATE		80	84	4
BROWN & GRAY CLAY		84	178	94
PARTIALLY CEMENTED	**	178	203	25
CLAY & GRAVEL		203	216	13
CEMENTED CONGLOMERATE		216	234	18
CLAY & GRAVEL		234	250	16
CEMENTED CONGLOMERATE		250	295	45
CLAY & GRAVEL		295	306	11
CLAY & SAND		306	342	36
CEMENTED		342	398	56
CLAY, SAND, & GRAVEL		398	405	7
CLAY, SAND, GRAVEL		405	450	45

RECEIVED
AUG 11 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 07-14-94, 19
Date completed 07-23-94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40+		8 HOURS

8. WELL CONSTRUCTION
Depth Drilled 450 Feet Depth Cased 450 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8				

Perforations:
Type perforation TORCH
Size perforation 6" X 3/16 X 4PF
From 250 feet to 450 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 230 FT.
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ALLEN DRILLING, INC. (Contractor)
Address 4847 S. VALLEY VIEW BLVD. (Contractor)
LAS VEGAS, NEVADA 89103

Nevada contractor's license number issued by the State Contractor's Board 0018916

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661

Signed Donald Le Well
By driller performing actual drilling on site or contractor

Date 08-04-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627