


WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 45405
 Permit No. 1163
 Basin 10928



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 10928

1. OWNER Dan Higley ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 SE 1/4 Sec 32 T. 24 N/S R. 57 E County _____
 PERMIT NO. APN# 201-32-891-007 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dirt + Rocks		0	20	20
Consolidated Cemented gravel		20	114	94
Water		114	120	6
Cemented gravel with loose breaks about every 4 or 5 feet containing loose sand & gravel		120	205	85

8. WELL CONSTRUCTION
 Depth Drilled 205 Feet Depth Cased 205 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 205 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>205</u>

Perforations:
 Type perforation 5/8 threaded
 Size perforation 1/2" x 6'
 From 8 feet to _____ feet
 From 114 feet to 205 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

RECEIVED
 JUL 01 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started _____, 19____
 Date completed _____, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>No Draw Down</u>	<u>2 HOURS</u>

9. WATER LEVEL
 Static water level 40 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge
 Name Emmett Ent Contractor
 Address 630 Pelly
Joe Higley Contractor
 Nevada contractor's license number issued by the State Contractor's Board 27050
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 171
 Signed H.V. Weimer
 By driller performing actual drilling on site or contractor
 Date 6-17-94

