WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45416
Permit No.
Basin 212

NOTICE OF INTENT NO. 12933

1. OWNER Byron Robinson
MAILING ADDRESS
ADDRESS AT WELL LOCATION NA

2. LOCATION NW ¼ NW ¼ Sec. 30 T. 19 S N/S R. 60 E CLARK County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	8	
Cemented Gravel		8	12	
Clay &Gravel		12	35	
Cemented Gravel		35	50	
Boulders		50	210	
Clay & Gravel		210	485	
Gravel & Water	xx	485	500	
Cemented Gravel		500	560	
Gravel & Water	xx	560	600	
Cemented Gravel		600	645	
Gravel & Water	xx	645	680	
Cemented Gravel		680	694	

RECEIVED
JUN 30 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 6-28-94, 19
Date completed 6-10-94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 694 Feet Depth Cased 694 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches	0 Feet	694 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	694

Perforations:
Type perforation Factory
Size perforation 3/16 X 8 ROW
From 574 feet to 594 feet
From 654 feet to 674 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 80
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 428 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 5360 N. Bonita Vista ST. (Contractor)
Las Vegas, Nev. 89129
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V. H. Dimick (By driller performing actual drilling on site or contractor)
Date 6-27-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627