

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 45417  
 Permit No. \_\_\_\_\_  
 Basin 212



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12460

1. OWNER Steve Jones ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3021 S. Valley View Suite 113 Inspiration & Blue Diamond  
Las Vegas, Nev. 89102

2. LOCATION SE 1/4 NE 1/4 Sec 23 T 22 N/S R 60 E Clark County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt, sand & gravel		0	18	18
cemented conglomerate		18	25	7
sand & gravel		25	59	34
cemented conglomerate		59	68	9
partially cemented		68	110	42
sand & gravel		110	153	43
cemented conglomerate		153	162	9
sand, gravel some clay	X	162	248	86
partially cemented		248	300	52
clay & gravel		300	348	48
partially cemented gravel		348	378	30
red sand stone		378	414	36
sand & gravel some clay		414	462	48
cemented gravel		462	488	26
red sandstone w/layers		488	850	362
of clay and gravel				
gravel conglomerate	XXX	850	862	12
grey lime stone		682	875	13

8. WELL CONSTRUCTION  
 Depth Drilled 875 Feet Depth Cased 875 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 875 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8"		.188	0	875

Perforations:  
 Type perforation torch  
 Size perforation 3/8x6" x 4 per foot  
 From 675 feet to 875 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 280' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Allen Drilling Inc. Contractor  
 Address 4847 So. Valley View Blvd. Contractor  
Las Vegas, Nev. 89103

Nevada contractor's license number 0018917  
 issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661

Signed Donald R. Walsh  
 By driller performing actual drilling on site or contractor

Date June 15, 1994

Date started May 15 19 94  
 Date completed June 11 19 94

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
@ 850'	100		

RECEIVED  
 JUL 05 1994  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

