


WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Log No. 45425
 Permit No. 57514
 Basin

1. OWNER Thomas & Ann Webster ADDRESS AT WELL LOCATION Gary & Hauk
 MAILING ADDRESS 650 6550 So. Procyon
Las Vegas, NV 89118-4537
 2. LOCATION SE 1/4 SE 1/4 Sec 24 T 22 R 60 E Clark County
 PERMIT NO. 57514 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil w/cobblestones		0	20	20
Cobbles, sand, grav., bldrs		20	40	20
Sand, grav, clay, bldrs		40	60	20
Boulders		60	80	20
cem. grav & bldrs		80	100	20
Sand, some clay & silt		100	140	40
Alluv. mat, rocks, sand, clay		140	170	30
Clay & silt		170	185	15
Clay, sand, silt, sm. bldrs		185	200	15
Clay		200	280	80
Cem. gravel		280	290	10
Sandstone		290	295	5
Cem. sand & gravel		295	330	35
Sand & small gravels		330	440	110
Red sandstone		440	455	15
Sand & small gravels		455	485	30
Red sandstone		485	489	4
Cemented gravel		489	529	40
Sand & silt		529	549	20
Sand, cem. stringers		549	584	55
Red sandstone		584	601	17

8. WELL CONSTRUCTION
 Depth Drilled 601 Feet Depth Cased 601 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 601 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	15.64	.188	+1	601

Perforations:
 Type perforation Mill slots
 Size perforation 1/8 x 2 1/8" 8 rows
 From 509 feet to 529 feet
 From 549 feet to 599 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 55'
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From 55 feet to 601 feet

RECEIVED
 JUL 08 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV

9. WATER LEVEL
 Static water level 315 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started June 9, 1994
 Date completed July 6, 1994

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name THOMPSON DRILLING CO., INC. Contractor
 Address 4185 West Harmon Contractor
Las Vegas, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board 4286A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1686
 Signed Richard K. Thompson
 By driller performing actual drilling on site or contractor
 Date July 7, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			