WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45445
Permit No.
Basin 163

NOTICE OF INTENT NO. 9944

1. OWNER Richard & Brenda Huchison
MAILING ADDRESS P.O. BOX 19924 Jean Nev. 89019
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ NE ¼ Sec 22 T 24-S N/S R 56 E Clark County
PERMIT NO. (Issued by Water Resources) APM 580-160-043 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Red Clay/Sand		5	21	16
Gravel Sand Red Clay		21	35	14
Tan Clay/ Gravel		35	52	17
White Clay/Gravel		52	74	22
Rock & Sand		74	88	14
Sand & Clay		88	94	6
Rock & Sand		94	108	14
Sand		108	124	16
Red Clay		124	158	34
Tan Clay		158	175	17

RECEIVED
JUL 26 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started June 6, 19 94
Date completed July 8, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
89	20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	175 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	18lbs.	.188	0	175

Perforations:
Type perforation Torch Cut
Size perforation ¼ in width 8 in long
From 133 feet to 175 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 175 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg (Contractor)
Address HCR 77 Box 36525 Pahrump, Nev. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1917
Signed Charles Nyberg EDDIE JOE OATS
By driller performing actual drilling on site or contractor
Date 7-17-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627