WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

in book

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45484
Permit No.
Basin 212

NOTICE OF INTENT NO. 13060

1. OWNER CAL NEV PIPELINE CO.
MAILING ADDRESS 412 HOSPITALITY STE 202
PO BOX 6346, SAN BERNARDINO CA 92346

ADDRESS AT WELL LOCATION MIDDLE OF INTERSECTION AT VALLEY VIEW & HACIENDA

2. LOCATION SE ¼ NE ¼ Sec. 30 T 21 N/S R 61 E CLARK County
PERMIT NO. MO-2400 (Issued by Water Resources) | C.C. ROW (Parcel No.) | (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE RW-13
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL		0	1	1
SANDY SILT		1	6	5
SILTY SAND		6	16	10
SANDY TO CLAYEY SILT		16	20	4
SILTY SAND		20	37	17
CALICHE		37	39	2
SANDY SILT		39	42	3
CALICHE		42	44	2
CLAYEY SILT		44	47.5	3.5
CALICHE		47.5	50	2.5
SILT		50	55	5
CLAY		55	80	25
CEMENTED GRAVEL		80	84	4

RECEIVED
MAR 17 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started FEBRUARY 27, 19 94
Date completed FEBRUARY 27, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 84 Feet Depth Cased 84 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	84 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.6	0.337	0	84

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 49 feet to 84 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-37'/37-44' BENTON
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 44 feet to 84 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGH (Contractor)
Address 4670 SO. POLARIS AVE (Contractor)
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
Signed (By driller performing actual drilling on site or contractor)
Date MARCH 15, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627