

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 4550  
 Permit No. 212  
 Basin 212

NOTICE OF INTENT NO. 12459

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER Joyce Covert ADDRESS AT WELL LOCATION Richmar/Valley View  
 MAILING ADDRESS Charlie Erias

2. LOCATION NE 1/4 SE 1/4 Sec 19 T. 22 N/S R. 61 E Clark County Clark  
 PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
silt sand gravel		0	32	32
cemented congl.		32	35	3
sand & gravel		35	70	35
cemented congl.		70	78	8
gravel		78	102	24
cemented congl.		102	112	10
sand & gravel		112	144	32
gravel & some clays		144	189	45
partially congl.		189	262	93
red & gravel (sand stone)	X	262	305	43
sand & gravel		305	320	15
gravel congl.	X	320	370	50
cemented		370	378	8
gravel		378	410	23

8. WELL CONSTRUCTION  
 Depth Drilled 410 Feet Depth Cased 410 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 410 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	410

Perforations:  
 Type perforation Torch  
 Size perforation \_\_\_\_\_  
 From 260 feet to 410 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 250 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ALLEN DRILLING, INC.  
 Address 4847 So. Valley View Blvd. LAS VEGAS, NEVADA 89103

Nevada contractor's license number 0018917  
 issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661

Signed Donald Walk  
 By driller performing actual drilling on site or contractor

Date 6-6-94

Date started 5-5 1994  
 Date completed 5-14 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20+</u>	<u>?</u>	<u>6 HRS</u>

RECEIVED  
 JUN 10 1994  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

