WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45527
Permit No.
Basin 163

NOTICE OF INTENT NO. 9945

1. OWNER Les Stodghill
MAILING ADDRESS [redacted]
ADDRESS AT WELL LOCATION Sandy Valley

2. LOCATION SW ¼ NE ¼ Sec. 22 T. 24 N/S R. 56 E. Clark County
PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	3
Red Clay /Sand		3	9	6
Sandstone		9	12	3
Red Clay / Sand		12	21	9
Gravel & Sand		21	24	3
Tan Clay		24	48	24
Sandstone		48	52	4
White Clay / Gravel		52	81	29
White Clay		81	94	13
Rock & Sand		94	112	18
Tan Clay		112	125	13
Red Clay		125	146	21

RECEIVED
JUN 24 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started May 11, 1994
Date completed May 28, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
6	4	¼

8. WELL CONSTRUCTION
Depth Drilled 146 Feet Depth Cased 146 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	146 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17 lbs.	.188	0	146

Perforations:
Type perforation Torch Cut
Size perforation ¼" X 12" long
From 105 feet to 146 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 54
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 54 feet to 146 feet

9. WATER LEVEL
Static water level 112 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg (Contractor)
Address HCR 77 BOX 36525 (Contractor)
PAHRUMP NEV. 89041
Nevada contractor's license number 7484 issued by the State Contractor's Board
Nevada driller's license number 725 issued by the Division of Water Resources, the on-site driller Joe Oates 1917
Signed Charles Nyberg (By driller performing actual drilling on site or contractor)
Date 6-20-1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627