WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

in Book

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45529
Permit No.
Basin 163

NOTICE OF INTENT NO. 12308

1. OWNER Mike & Cathy Hashinger
MAILING ADDRESS
ADDRESS AT WELL LOCATION Woods & Santee Sandy Valley

2. LOCATION SW ¼ SW ¼ Sec. 23 T 24S N/S R 56 E Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 580-190-042 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		0	2	2
Calichie.		2	4	2
Clay		4	14	10
Calichie		14	17	3
Clay		17	29	12
Calichie		25	37	8
Clay		37	52	15
Calichie.		52	57	5
Clay		57	67	10
Calichie.		67	72	5
Clay.		72	78	6
Calichie.	WB	78	81	3
Clay.		81	91	10
Calichie.	"	91	94	3
Clay.		94	98	4
Calichie.	"	98	103	5
Clay		103	114	11
Calichie.	"	114	121	7
Clay		121	130	9
Limestone.		130	140	10
Clay		140	150	10

RECEIVED
MAY 25 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 5-3 1994
Date completed 5-5 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	150 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.97	.188	-1	150

Perforations:
Type perforation SAW
Size perforation 1/8 inch by 3 inch
From 110 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Contractor
Address HCR 78 Box 80358 Contractor
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1426
Signed [signature] By driller performing actual drilling on site or contractor
Date 5-18-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627