45532

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45532
Permit No.
Basin 163

NOTICE OF INTENT NO. 12028

1. OWNER Matthew & Christine Topliff
MAILING ADDRESS HCR 31 Box 320
Jean NV. 89019.
ADDRESS AT WELL LOCATION Lead. Ave & Paiute.
Sandy Valley.

2. LOCATION ~~SW~~ NW ¼ ~~NW~~ SW ¼ Sec. 25 T. 24S N/S R. 56 E. Clark County
PERMIT NO. (Issued by Water Resources) 580-230-024 (Parcel No.) (NEW # 200-25-201-008) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Calichie		5	8	3
Sand		8	14	6
Calichie		14	21	7
Clay		21	32	11
Calichie		32	36	4
Clay		36	46	10
Calichie		46	52	6
Clay		52	78	26
Calichie	WB	78	84	6
Clay		84	100	16
Calichie	WB	100	108	8
Clay		108	116	8
Calichie	WB	116	120	4
Clay		120	127	7
Calichie	WB	127	129	2
Clay		129	136	7
Calichie	WB	136	140	4

RECEIVED
JUN 2 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 5-10, 1994
Date completed 5-11, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12 1/4	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.57	.188	-0	140

Perforations:
Type perforation SAW.
Size perforation 1/8 inch by 3 inch
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1770
Signed [signature] (driller performing actual drilling on site or contractor)
Date 5-17-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627