WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45534
Permit No.
Basin 163

NOTICE OF INTENT NO. 12319

1. OWNER Gary & Mindy Larson
MAILING ADDRESS
ADDRESS AT WELL LOCATION 0 SAGE & Mercury Sandy Valley.

2. LOCATION NE ¼ SW ¼ Sec. 25 T. 21S N/S R. 56 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 580-230-057 Subdivision Name None

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		0	5	5
Calichie.		5	10	5
Clay.		10	19	9
Calichie.		19	22	3
Clay.		22	31	9
Calichie.		31	34	3
Clay.		34	47	13
Calichie.		47	52	5
Clay & Sand.		52	69	17
Calichie.	W.B.	69	72	3
Clay.		72	81	9
Calichie.	"	81	86	5
Clay.		86	95	9
Calichie	"	95	102	7
Clay.		102	115	13
Calichie.	"	115	118	3
Clay.		118	126	8
Calichie.	"	126	131	5
Clay.		131	135	4
Calichie	"	135	140	5

RECEIVED
MAY 17 1994
Div. of Water Resources
Branch Offices - Las Vegas, NV

Date started 5-2, 1994
Date completed 5-5, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.57	.188	-1	140

Perforations:
Type perforation SAW
Size perforation ⅛ inch by 3 inch.
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 Ft.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Contractor
Address HCR 78 Box 80358 Contractor
Pahrump NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1476
Signed By driller performing actual drilling on site or contractor
Date 5-12-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627