

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13595

1. OWNER Lou Ann Muhl ADDRESS AT WELL LOCATION Silver Ln Sandy Valley
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 NE 1/4 Sec. 17 T. 25S N/S R. 57 E Clark County
 PERMIT NO. 596-420-631 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	4	4
clay		4	34	30
caliche		34	41	7
clay		41	84	43
caliche		84	86	2
clay		86	116	30
Limestone	WB	116	140	24

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/8</u>	<u>16.44</u>	<u>.184</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory Saw Cut
 Size perforation 1/2"
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 40 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HCR 78 Box 80354 Contractor
Primm NV 89011
 Nevada contractor's license number issued by the State Contractor's Board 30840
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1647
 Signed Thomas D...
 By driller performing actual drilling on site or contractor
 Date 8-29-94

Date started 7-25 1994
 Date completed 7-28 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
 OCT 04 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV

