

OFFICE USE ONLY
 Log No. 45574
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 13728

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER John Tyler ADDRESS AT WELL LOCATION Lot 6 W. 10th way
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 NE 1/4 Sec 33 T. 20S N/S R. 53 E N/E County _____
 PERMIT NO. 35-471-648 Issued by Water Resources Parcel No. _____ Subdivision Name Starlight Manor

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	12	12
caliche		12	16	2
Clay		16	36	20
caliche		36	38	2
Clay		38	62	24
caliche	WB	62	65	3
Clay		65	86	21
caliche	WB	86	90	4
Clay		90	114	24
caliche	WB	114	117	3
Clay		117	131	14
caliche	WB	131	133	2
Clay		133	140	7

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 8 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory Sawcut
 Size perforation 1/8 x 3
 From 100 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 140 feet

RECEIVED

SEP 07 1994

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 8-12, 1994
 Date completed 8-17, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 56 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address 10278 Box 80358 Contractor
Pahrump NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas D...
 By driller performing actual drilling on site or contractor
 Date 8-25-94