

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO13703

1. OWNER JOHN MURPHY ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____ LOT 65 MURPHY ST
PAHRUMP NV 89041

2. LOCATION NE $\frac{1}{4}$ NW $\frac{1}{4}$ Sec. 13 T. 20S N/S R. 52 E. NYE County
 PERMIT NO. 28-703-13 CHARLESTON PARK Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	6	6
CALICHIE		6	8	2
CLAY		8	31	23
CALICHIE		31	40	9
CLAY		40	56	16
CALICHIE	WB	56	59	3
CLAY		59	68	9
CALICHIE	WB	68	76	8
CLAY		76	91	15
CALICHIE	WB	91	94	3
CLAY		94	113	19
CALICHIE	WB	113	115	2
CLAY		115	126	11
CALICHIE	WB	126	130	4
CLAY		130	137	7
CALICHIE	WB	137	140	3
		140		140

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12.25 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85/8	16.9	.188	0	140

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 1 1/8 x 3"
 From _____ feet to _____ feet
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 47 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

RECEIVED
 SEP 07 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started _____ 19____
 Date completed 7-15-94 19____
7-19-94

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO., INC. Contractor
 Address HCR 78 BOX 8058 Contractor
PAHRUMP NV 89041

Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 8-26-94