



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO.13307

1. OWNER KATSUMI MORIMOTO ADDRESS AT WELL LOCATION LA FAYETTE ST  
 MAILING ADDRESS PAHRUMP NV 89041

2. LOCATION SE 1/4 NW 1/4 Sec. 15 T. 20S N/S R. 53 E. NYE County NYE  
 PERMIT NO. 35-321-14 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	4	4
CALICHIE		4	7	3
CLAY		7	29	22
CALICHIE		29	32	3
CLAY		32	47	15
CALICHIE	WB	47	51	4
CLAY		51	73	22
CALICHIE	WB	73	85	12
CLAY		85	91	6
CALICHIE	WB	91	94	3
CLAY		94	115	21
CALICHIE	WB	115	117	2
CLAY		117	122	5
CALICHIE	WB	122	126	4
CLAY		126	135	9
CALICHIE	WB	135	140	5
		140		140

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12.25 Inches To 0 Feet 140 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85/8	16.9	1.88	0	140

Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 1 1/8 X 3"  
 From 100 feet to 120 feet  
 From 100 feet to 120 feet  
 From 100 feet to 120 feet  
 From 100 feet to 120 feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 51 feet below land surface  
 Artesian flow 51 G.P.M. P.S.I.  
 Water temperature 51 °F Quality 51

RECEIVED

SEP 07 1994

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 6-24-94, 19\_\_\_\_  
 Date completed 6-26-94, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO., INC. Contractor  
 Address HCR 78 BOX 8035 Contractor  
PAHRUMP NV 89041

Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Thomas D...  
 By driller performing actual drilling on site or contractor  
 Date 6-26-94