

Log No. 45587
 Permit No. _____
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 3310

1. OWNER MIKE BEATTY ADDRESS AT WELL LOCATION 3380S PAHRUMP VALLEY BLVD
 MAILING ADDRESS _____ PAHRUMP NV 89041

2. LOCATION SE NE 1/4 Sec 34 T20S N/S R 53 E NYE County _____
 PERMIT NO. 40-627-34 CALVADA VALLEY Subdivision Name _____
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	4	4
CALICHIE		4	8	4
CLAY		8	26	18
CALICHIE		26	29	3
CLAY		29	51	22
CALICHIE	WB	51	53	2
CLAY		53	69	16
CALICHIE	WB	69	72	3
CLAY		72	95	23
CALICHIE	WB	95	99	4
CLAY		99	117	18
CALICHIE	WB	117	120	3
CLAY		120	131	11
CALICHIE	WB	131	134	3
CLAY		134	138	4
CALICHIE	WB	138	140	2
		140		140

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 140
12.25 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85\8	16.9	.188	0	140

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 1\8 X 3"
 From 100 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 5.4 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO., INC.
 Contractor

Address HCR 78 BOX 80358
PAHRUMP NV 89041
 Contractor

Nevada contractor's license number 30880
 issued by the State Contractor's Board

Nevada driller's license number issued by the
 Division of Water Resources, the on-site driller 1642

Signed Thomas P. ...
 By driller performing actual drilling on site or contractor

Date 6-26-94

RECEIVED
 SEP 07 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 6-24-94, 19____
 Date completed 6-28-94, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			