

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **13723**

1. OWNER ALLEN RUSSELL ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____ 4190 W. SUNSET
 _____ PAHRUMP NV 89041
 2. LOCATION NE $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 35 T. 19S N/S R. 52 E. NVE County _____
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND GRAVEL		0	34	34
CLAY		34	86	52
CLAY GRAVEL		86	111	25
CALICHIE		111	116	5
CLAY		116	127	11
CALICHIE	WB	127	130	3
CLAY		130	136	6
CALICHIE	WB	136	140	4
		140	140	

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12.25 Inches _____ Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>85/8</u>	<u>16.9</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 1 1/8" X 3"
 From _____ feet to _____ feet
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From X feet to _____ feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow 54 G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO., INC. Contractor
 Address HCR 78 BOX 8088 Contractor
PAHRUMP NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 8-26-94

Date started _____, 19____
 Date completed 8-4-94, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED

SEP 07 1994

Div. of Water Resources
 Branch Office - Las Vegas, NV