

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 45593
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10917

1. OWNER John Johannes ADDRESS AT WELL LOCATION UNIT #3 Block #5 Lot #3
 MAILING ADDRESS PAHRUMP NEV JARVIS ST
Box 8013

2. LOCATION N 1/2 1/4 Sec 28 T. 19 S N/S R. 53 E N 1/4 E County _____
 PERMIT NO. 29-901-303 BELL VISTA Sub
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	1	1
BRN Clay		1	11	10
HARD BRN Clay		10	24	14
BRN Clay		24	46	22
HARD GREY Caliche		46	51	5
BRN Clay	WB	51	69	18
HARD GREY Clay		69	81	12
BRN Clay	WB	81	120	39
BRN Clay	WB	120	150	30
HARD GREY Clay		150	160	10

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From To
12 1/2 Inches 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>17.11</u>	<u>1.88</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation Torch Cut
 Size perforation 1/4" x 6"
 From 110 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 160 feet to 50 feet

9. WATER LEVEL
 Static water level 65 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ron Nailon Drilling Contractor
 Address Box 265 PAHRUMP NEV 89041 Contractor

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift
 G.P.M. Draw Down (Feet Below Static) Time (Hours)

DATE STARTED SEPT 10 1994
 DATE COMPLETED SEPT 14 1994

RECEIVED
 SEP 21 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Nevada contractor's license number issued by the State Contractor's Board 0035704
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1625
 Signed Ron Nailon
 By driller performing actual drilling on site or contractor
 Date SEPT 15 1994