WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45598
Permit No.
Basin 212

NOTICE OF INTENT NO. 13718

1. OWNER NEVADA DIVISION OF ENVIRONMENTAL PROTECTION, 123 WEST NYE
MAILING ADDRESS CARSON CITY NV 89710
ADDRESS AT WELL LOCATION 1229 EAST FLAMINGO RD, LAS VEGAS NV

2. LOCATION NW ¼ NW ¼ Sec. 23 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. MO-2464 Issued by Water Resources
162-23-101-001 Parcel No.
Subdivision Name

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE: [ ] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE: [ ] Cable [ ] Rotary [ ] RVC [ ] Air [X] Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT/FILL		0	2.5	2.5
SANDY SILT		2.5	5	2.5
SILTY SAND		5	13	8
CLAYEY SILT		13	15	2
SILTY CLAY		15	25	10

RECEIVED
AUG 10 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started AUGUST 3 1994
Date completed AUGUST 3 1994

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
8	0	25

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	25

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 10 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 0-6'/6-8' BENTONITE
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 8 feet to 25 feet

9. WATER LEVEL
Static water level 12.3 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGH
Contractor
Address 4670 SO. POLARIS AVE
Contractor
LAS VEGAS NV 89103

Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
Signed
By driller performing actual drilling on site or contractor
Date AUGUST 8 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627